



BASTILLE - PRISON GRADE INSTALLATION INSTRUCTIONS

When using electrical equipment, always follow basic safety precautions, including the following:

THIS PRODUCT MUST BE INSTALLED IN ACCORDANCE WITH THE APPLICABLE INSTALLATION CODE BY A PERSON FAMILIAR WITH THE CONSTRUCTION AND OPERATION OF THE PRODUCT AND THE HAZARDS INVOLVED. DISCONNECT POWER TO ALL CIRCUITS BEFORE WIRING FIXTURE. INSTALL IN ACCORDANCE WITH ALL NATIONAL, STATE, AND LOCAL CODES. DO NOT CONNECT TO AN UNGROUNDED SUPPLY. READ ALL FIXTURE MARKINGS AND LABELS TO ENSURE CORRECT INSTALLATION OF FIXTURE. SUPPLEMENTAL INSTRUCTIONS MAY BE LOCATED ON THE FIXTURE, IN ADDITION TO THIS INSTRUCTION SHEET, REGARDING ORIENTATION, OR MOUNTING RESTRICTIONS.



SURFACE MOUNT INSTALLATION

- Disconnect the quick connect from the fixture. While removed, wire the quick connect to the designated supply wires. Connect the leads from the fixture to the power supply leads, making sure to use connectors that are suitable for the number of wires and the wire gauge. Be sure to make all connections in the junction box, and not inside the fixture. Colored/Black wires connect to the supply conductor, while the white fixture lead connects to the neutral supply conductor. Ensure that grounding wire is properly grounded.
- Place the surface mount fixture over the junction box. Map hole location and drill pilot holes in the mounting surface. Use proper fasteners and anchors (not supplied) in respect to the fixtures weight. Mount the fixture base to the building.
- Pull the connection through the access hole and mate the connections together. Push the quick connect back inside the electrical junction box.

SEE NEXT PAGE FOR DIMENSIONS 

